



Indoor Luminaire Photometric Data


Character Parameter

Lamp Speciality Parameter		Luminaire Speciality Parameter	
Rated Flux(lm):	457.000	Luminary Flux(lm):	494.044
Rated Power(W):		Luminary Efficiency:	108.11%
Rated Voltage(V):		Luminary EER(lm/W):	83.679
Tested Power(W):	5.904	Max. Candela(cd):	1521.960
Lamps' Inside:	1	Max Cand@Ang. (°):	C=270.0 γ=2.0
Tested Electrics(V, A, pf):	240.6, 0.028, 0.852	Beam Angle(50%Imax):	18.8(°)
Lamp Size(W*L*H):	0.050m*0.000m*0.000m	Left=-7.8°, Right=11.0°	IRF(%):
			672.165




2D Plane Light Intensity Distribution Curve

Test Machine:GON-2000 Test Date: 2018/03/06



3D Light Intensity Distribution Modal

3D Light Intensity Distribution Modal



Curves: 3D Model — Fixture — Vert. HUD — Hori. HUD —
View Angles: Orient:0 Tilt:0 Roll:0 Spin:0

Zonal Flux Tabulation

Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
0.0-1.0	1.41	1.41	0.31	0.31	47.0-48.0	2.25	453.93	0.49	99.33
1.0-2.0	4.14	5.55	0.91	1.22	48.0-49.0	1.93	455.86	0.42	99.75
2.0-3.0	6.65	12.20	1.45	2.67	49.0-50.0	1.71	457.56	0.37	100.12
3.0-4.0	8.83	21.04	1.93	4.60	50.0-51.0	1.53	459.09	0.33	100.46
4.0-5.0	10.63	31.67	2.33	6.93	51.0-52.0	1.37	460.47	0.30	100.76
5.0-6.0	12.02	43.68	2.63	9.56	52.0-53.0	1.24	461.71	0.27	101.03
6.0-7.0	12.99	56.68	2.84	12.40	53.0-54.0	1.12	462.83	0.25	101.28
7.0-8.0	13.57	70.25	2.97	15.37	54.0-55.0	1.03	463.86	0.23	101.50
8.0-9.0	13.82	84.07	3.02	18.40	55.0-56.0	0.96	464.82	0.21	101.71
9.0-10.0	13.75	97.82	3.01	21.40	56.0-57.0	0.90	465.72	0.20	101.91
10.0-11.0	13.48	111.30	2.95	24.35	57.0-58.0	0.85	466.57	0.19	102.09
11.0-12.0	13.13	124.43	2.87	27.23	58.0-59.0	0.80	467.37	0.17	102.27
12.0-13.0	12.77	137.20	2.79	30.02	59.0-60.0	0.76	468.12	0.17	102.43
13.0-14.0	12.40	149.60	2.71	32.74	60.0-61.0	0.72	468.84	0.16	102.59
14.0-15.0	12.01	161.61	2.63	35.36	61.0-62.0	0.69	469.53	0.15	102.74
15.0-16.0	11.62	173.23	2.54	37.91	62.0-63.0	0.66	470.18	0.14	102.89
16.0-17.0	11.27	184.50	2.47	40.37	63.0-64.0	0.63	470.82	0.14	103.02
17.0-18.0	10.94	195.44	2.39	42.77	64.0-65.0	0.61	471.42	0.13	103.16
18.0-19.0	10.65	206.09	2.33	45.10	65.0-66.0	0.58	472.01	0.13	103.28
19.0-20.0	10.40	216.49	2.28	47.37	66.0-67.0	0.56	472.57	0.12	103.41
20.0-21.0	10.21	226.70	2.24	49.61	67.0-68.0	0.55	473.12	0.12	103.53
21.0-22.0	10.08	236.79	2.21	51.81	68.0-69.0	0.53	473.65	0.12	103.64
22.0-23.0	10.00	246.79	2.19	54.00	69.0-70.0	0.51	474.16	0.11	103.76
23.0-24.0	9.95	256.73	2.18	56.18	70.0-71.0	0.50	474.66	0.11	103.86
24.0-25.0	9.92	266.65	2.17	58.35	71.0-72.0	0.49	475.15	0.11	103.97
25.0-26.0	9.89	276.54	2.16	60.51	72.0-73.0	0.47	475.62	0.10	104.07
26.0-27.0	9.86	286.40	2.16	62.67	73.0-74.0	0.46	476.08	0.10	104.17
27.0-28.0	9.84	296.24	2.15	64.82	74.0-75.0	0.44	476.52	0.10	104.27
28.0-29.0	9.82	306.06	2.15	66.97	75.0-76.0	0.43	476.95	0.09	104.37
29.0-30.0	9.81	315.87	2.15	69.12	76.0-77.0	0.42	477.37	0.09	104.46
30.0-31.0	9.82	325.69	2.15	71.27	77.0-78.0	0.40	477.78	0.09	104.55
31.0-32.0	9.85	335.54	2.16	73.42	78.0-79.0	0.39	478.17	0.09	104.63
32.0-33.0	9.90	345.44	2.17	75.59	79.0-80.0	0.38	478.54	0.08	104.71
33.0-34.0	9.96	355.41	2.18	77.77	80.0-81.0	0.37	478.91	0.08	104.79
34.0-35.0	10.03	365.44	2.20	79.96	81.0-82.0	0.35	479.26	0.08	104.87
35.0-36.0	10.09	375.53	2.21	82.17	82.0-83.0	0.34	479.60	0.07	104.95
36.0-37.0	10.09	385.62	2.21	84.38	83.0-84.0	0.33	479.93	0.07	105.02
37.0-38.0	9.94	395.55	2.17	86.55	84.0-85.0	0.31	480.24	0.07	105.09
38.0-39.0	9.58	405.13	2.10	88.65	85.0-86.0	0.30	480.54	0.07	105.15
39.0-40.0	9.04	414.17	1.98	90.63	86.0-87.0	0.28	480.82	0.06	105.21
40.0-41.0	8.27	422.44	1.81	92.44	87.0-88.0	0.26	481.09	0.06	105.27
41.0-42.0	7.32	429.76	1.60	94.04	88.0-89.0	0.24	481.33	0.05	105.32
42.0-43.0	6.30	436.06	1.38	95.42	89.0-90.0	0.23	481.56	0.05	105.37
43.0-44.0	5.25	441.32	1.15	96.57	90.0-91.0	0.21	481.77	0.05	105.42
44.0-45.0	4.25	445.57	0.93	97.50	91.0-92.0	0.21	481.98	0.05	105.47
45.0-46.0	3.39	448.96	0.74	98.24	92.0-93.0	0.20	482.18	0.04	105.51
46.0-47.0	2.72	451.67	0.59	98.83	93.0-94.0	0.20	482.37	0.04	105.55


EQUIVALENT • IES Indoor Report

Photometric Filename:KA6R15BTC.IES


Zonal Flux Tabulation - (Cont.)

Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
94. 0-95. 0	0. 19	482. 56	0. 04	105. 59	141. 0-142. 0	0. 17	489. 82	0. 04	107. 18
95. 0-96. 0	0. 19	482. 75	0. 04	105. 63	142. 0-143. 0	0. 17	489. 99	0. 04	107. 22
96. 0-97. 0	0. 18	482. 93	0. 04	105. 67	143. 0-144. 0	0. 17	490. 16	0. 04	107. 26
97. 0-98. 0	0. 18	483. 11	0. 04	105. 71	144. 0-145. 0	0. 17	490. 34	0. 04	107. 29
98. 0-99. 0	0. 17	483. 28	0. 04	105. 75	145. 0-146. 0	0. 17	490. 51	0. 04	107. 33
99. 0-100. 0	0. 17	483. 45	0. 04	105. 79	146. 0-147. 0	0. 17	490. 68	0. 04	107. 37
100. 0-101. 0	0. 17	483. 62	0. 04	105. 82	147. 0-148. 0	0. 17	490. 85	0. 04	107. 41
101. 0-102. 0	0. 16	483. 78	0. 04	105. 86	148. 0-149. 0	0. 17	491. 01	0. 04	107. 44
102. 0-103. 0	0. 16	483. 94	0. 04	105. 90	149. 0-150. 0	0. 17	491. 18	0. 04	107. 48
103. 0-104. 0	0. 16	484. 10	0. 03	105. 93	150. 0-151. 0	0. 16	491. 34	0. 04	107. 52
104. 0-105. 0	0. 16	484. 26	0. 03	105. 96	151. 0-152. 0	0. 16	491. 51	0. 04	107. 55
105. 0-106. 0	0. 16	484. 41	0. 03	106. 00	152. 0-153. 0	0. 16	491. 67	0. 03	107. 59
106. 0-107. 0	0. 15	484. 57	0. 03	106. 03	153. 0-154. 0	0. 16	491. 82	0. 03	107. 62
107. 0-108. 0	0. 15	484. 72	0. 03	106. 07	154. 0-155. 0	0. 15	491. 97	0. 03	107. 65
108. 0-109. 0	0. 15	484. 87	0. 03	106. 10	155. 0-156. 0	0. 15	492. 12	0. 03	107. 69
109. 0-110. 0	0. 15	485. 02	0. 03	106. 13	156. 0-157. 0	0. 14	492. 27	0. 03	107. 72
110. 0-111. 0	0. 15	485. 17	0. 03	106. 16	157. 0-158. 0	0. 14	492. 41	0. 03	107. 75
111. 0-112. 0	0. 15	485. 32	0. 03	106. 20	158. 0-159. 0	0. 14	492. 54	0. 03	107. 78
112. 0-113. 0	0. 15	485. 46	0. 03	106. 23	159. 0-160. 0	0. 13	492. 67	0. 03	107. 81
113. 0-114. 0	0. 15	485. 61	0. 03	106. 26	160. 0-161. 0	0. 13	492. 80	0. 03	107. 83
114. 0-115. 0	0. 15	485. 75	0. 03	106. 29	161. 0-162. 0	0. 12	492. 92	0. 03	107. 86
115. 0-116. 0	0. 14	485. 90	0. 03	106. 32	162. 0-163. 0	0. 12	493. 04	0. 03	107. 89
116. 0-117. 0	0. 14	486. 04	0. 03	106. 36	163. 0-164. 0	0. 11	493. 15	0. 02	107. 91
117. 0-118. 0	0. 14	486. 19	0. 03	106. 39	164. 0-165. 0	0. 10	493. 25	0. 02	107. 93
118. 0-119. 0	0. 14	486. 33	0. 03	106. 42	165. 0-166. 0	0. 10	493. 35	0. 02	107. 95
119. 0-120. 0	0. 14	486. 47	0. 03	106. 45	166. 0-167. 0	0. 09	493. 45	0. 02	107. 97
120. 0-121. 0	0. 14	486. 62	0. 03	106. 48	167. 0-168. 0	0. 09	493. 53	0. 02	107. 99
121. 0-122. 0	0. 14	486. 76	0. 03	106. 51	168. 0-169. 0	0. 08	493. 61	0. 02	108. 01
122. 0-123. 0	0. 14	486. 90	0. 03	106. 54	169. 0-170. 0	0. 07	493. 69	0. 02	108. 03
123. 0-124. 0	0. 14	487. 05	0. 03	106. 57	170. 0-171. 0	0. 07	493. 75	0. 01	108. 04
124. 0-125. 0	0. 14	487. 19	0. 03	106. 61	171. 0-172. 0	0. 06	493. 81	0. 01	108. 06
125. 0-126. 0	0. 14	487. 33	0. 03	106. 64	172. 0-173. 0	0. 05	493. 87	0. 01	108. 07
126. 0-127. 0	0. 15	487. 48	0. 03	106. 67	173. 0-174. 0	0. 05	493. 91	0. 01	108. 08
127. 0-128. 0	0. 15	487. 63	0. 03	106. 70	174. 0-175. 0	0. 04	493. 95	0. 01	108. 09
128. 0-129. 0	0. 15	487. 77	0. 03	106. 73	175. 0-176. 0	0. 03	493. 99	0. 01	108. 09
129. 0-130. 0	0. 15	487. 92	0. 03	106. 77	176. 0-177. 0	0. 03	494. 01	0. 01	108. 10
130. 0-131. 0	0. 15	488. 07	0. 03	106. 80	177. 0-178. 0	0. 02	494. 03	0. 00	108. 10
131. 0-132. 0	0. 15	488. 22	0. 03	106. 83	178. 0-179. 0	0. 01	494. 04	0. 00	108. 11
132. 0-133. 0	0. 15	488. 37	0. 03	106. 86	179. 0-180. 0	0. 00	494. 04	0. 00	108. 11
133. 0-134. 0	0. 15	488. 53	0. 03	106. 90					
134. 0-135. 0	0. 16	488. 68	0. 03	106. 93					
135. 0-136. 0	0. 16	488. 84	0. 03	106. 97					
136. 0-137. 0	0. 16	489. 00	0. 03	107. 00					
137. 0-138. 0	0. 16	489. 16	0. 04	107. 04					
138. 0-139. 0	0. 16	489. 32	0. 04	107. 07					
139. 0-140. 0	0. 17	489. 49	0. 04	107. 11					
140. 0-141. 0	0. 17	489. 66	0. 04	107. 15					

Rectangle ISO Lighting Intensity Diagram




Plane ISO-Illuminance Diagram




Working Plane Luminaire Mounting Height(m): 3.00
Working Plane Maximum Illuminance(lx): 168.80
Working Plane Maximum Illuminance Position(d/h):H-0.0 V-0.0

3D Plane ISO Illuminance Diagram

3D Plane Illuminance Modal




Space ISO Illuminance Diagram



Space Plane Maximum Illuminance and @Angle:1480.56lx,0.0deg
Plane Maximum Lighting Intensity and @Angle:1480.560cd,0deg


Illuminance-Distance Diagram



Indoor Luminance Limiting Curves


Glare Grade Table									
GI	Quality	Using Illuminance							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table									
Gama (deg)	45	50	55	60	65	70	75	80	85
C0	40688	16740	10683	8646	7962	7986	8731	10685	17425
C90	22226	12813	8640	7048	6383	6351	6889	8467	13212



Luminous Size: Length(m)=0.000 Width(m)=-0.050 Height(m)=0.000 Area(m^2)=0.001963
Luminous Type: Without Luminous Side
Luminous Curves: C0-C180 Color: — C90-C270 Color: —

Indoor Budgetary Estimate Table



Indoor Coefficient of Utilization Table

Coefficients of Utilization – Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC (%)	80				70				50			30			10			0
RhoW (%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization(%)																	
0	128	128	128	128	125	125	125	125	119	119	119	113	113	113	108	108	108	105
1	122	118	116	113	119	116	113	111	111	109	107	106	105	103	102	101	100	98
2	115	110	105	102	113	108	104	100	104	101	98	100	98	95	97	95	93	91
3	110	102	97	93	107	101	96	92	97	93	90	94	91	88	92	89	86	85
4	104	96	90	85	102	94	89	84	92	87	83	89	85	82	87	83	81	79
5	99	90	84	79	97	89	83	78	86	81	77	84	80	77	82	79	76	74
6	94	85	78	74	92	84	78	73	82	76	73	80	75	72	78	74	71	70
7	90	80	74	69	88	79	73	69	77	72	68	76	71	68	75	70	67	66
8	86	76	69	65	84	75	69	65	74	68	64	72	67	64	71	67	64	62
9	82	72	66	62	81	71	65	61	70	65	61	69	64	61	68	64	60	59
10	79	69	62	58	78	68	62	58	67	62	58	66	61	58	65	61	57	56

Unified Glare Rating Table

Unified Glare Rating Table											
Ceiling RCC		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size		Vewed crosswise					Vewed endwise				
X=2H	Y=2H	20.7	21.9	21.1	22.3	22.6	19.5	20.7	19.9	21.0	21.4
	Y=3H	20.7	21.8	21.1	22.2	22.6	19.5	20.5	19.9	20.9	21.4
	Y=4H	20.8	21.8	21.2	22.2	22.6	19.5	20.5	20.0	20.9	21.4
	Y=6H	20.9	21.8	21.3	22.2	22.7	19.6	20.5	20.1	21.0	21.4
	Y=8H	20.9	21.9	21.4	22.3	22.8	19.7	20.6	20.1	21.0	21.5
	Y=12H	21.1	21.9	21.6	22.4	22.9	19.8	20.6	20.2	21.1	21.6
X=4H	Y=2H	20.5	21.5	21.0	21.9	22.4	19.3	20.3	19.7	20.7	21.1
	Y=3H	20.6	21.5	21.0	21.9	22.4	19.4	20.2	19.8	20.7	21.1
	Y=4H	20.7	21.5	21.2	22.0	22.5	19.5	20.3	19.9	20.7	21.2
	Y=6H	20.9	21.7	21.4	22.1	22.7	19.7	20.4	20.2	20.9	21.4
	Y=8H	21.1	21.8	21.6	22.3	22.8	19.8	20.5	20.3	21.0	21.5
	Y=12H	21.3	22.0	21.9	22.5	23.0	20.0	20.7	20.6	21.2	21.7
X=8H	Y=4H	20.7	21.4	21.2	21.8	22.4	19.4	20.1	20.0	20.6	21.2
	Y=6H	21.0	21.6	21.5	22.1	22.8	19.8	20.4	20.3	20.9	21.5
	Y=8H	21.3	21.8	21.8	22.4	22.9	20.0	20.6	20.6	21.1	21.7
	Y=12H	21.7	22.2	22.2	22.7	23.3	20.4	20.9	20.9	21.4	22.1
X=12H	Y=4H	20.6	21.3	21.2	21.8	22.3	19.4	20.1	20.0	20.6	21.1
	Y=6H	21.0	21.6	21.6	22.1	22.7	19.8	20.4	20.4	20.9	21.5
	Y=8H	21.3	21.9	21.9	22.4	23.0	20.1	20.6	20.7	21.2	21.8
Variations with the objerver position at spacings											
S=1.0H		0.1/-0.1					0.2/-0.2				
S=1.5H		0.2/-0.3					0.3/-0.3				
S=2.0H		0.2/-0.3					0.3/-0.3				
Reduced UGR Table:											
Nordic Standard Table:		BK0					BK0				
Correction Value		1.1					1.1				

o the CIE Pub.117, data has been corrected, refers to the lamp's lumens 8.2flm.

Candela Tabulation

V/H	C0.0	C90.0	C180.0	C270.0
γ 0.0	1480.56	1480.56	1480.56	1480.56
γ 1.0	1467.29	1422.54	1454.36	1517.29
γ 2.0	1434.34	1333.27	1397.40	1521.96
γ 3.0	1371.95	1244.07	1315.74	1502.00
γ 4.0	1293.16	1144.29	1237.62	1446.53
γ 5.0	1211.43	1042.82	1146.39	1362.21
γ 6.0	1127.87	941.49	1040.78	1274.88
γ 7.0	1037.50	842.40	935.78	1172.57
γ 8.0	948.65	746.25	835.04	1067.59
γ 9.0	858.76	661.98	740.55	960.43
γ 10.0	766.82	587.19	648.79	853.82
γ 11.0	687.31	523.77	571.33	756.32
γ 12.0	614.33	471.12	509.44	672.57
γ 13.0	552.11	426.56	458.12	600.50
γ 14.0	498.16	387.18	415.87	536.00
γ 15.0	449.82	353.88	378.73	479.16
γ 16.0	408.92	324.24	345.15	432.96
γ 17.0	373.48	299.52	316.67	393.64
γ 18.0	342.22	279.22	290.83	359.00
γ 19.0	314.64	262.90	270.71	328.02
γ 20.0	291.21	249.43	254.20	301.66
γ 21.0	271.63	238.37	240.99	280.34
γ 22.0	255.29	228.65	229.86	262.20
γ 23.0	241.30	220.16	220.59	247.88
γ 24.0	230.24	211.98	212.08	235.72
γ 25.0	220.52	204.59	203.92	225.23
γ 26.0	211.96	197.18	196.86	215.85
γ 27.0	203.62	190.41	190.21	206.68
γ 28.0	196.55	184.60	183.73	198.52
γ 29.0	189.64	179.55	177.89	191.02
γ 30.0	183.71	174.75	172.65	184.08
γ 31.0	178.34	170.94	168.98	177.58
γ 32.0	174.33	167.87	165.19	172.10
γ 33.0	170.67	164.66	162.19	167.72
γ 34.0	167.61	161.85	157.95	164.17
γ 35.0	164.91	159.55	154.71	161.42
γ 36.0	161.85	154.44	152.13	158.78
γ 37.0	158.88	146.70	147.67	156.51
γ 38.0	154.80	133.82	138.26	154.12
γ 39.0	148.84	116.91	124.51	151.35
γ 40.0	136.25	100.75	112.31	145.51
γ 41.0	121.40	81.46	94.83	136.98
γ 42.0	105.53	64.22	78.72	122.49
γ 43.0	88.72	49.07	64.48	107.39
γ 44.0	70.75	38.42	48.96	88.84
γ 45.0	56.49	30.86	36.32	71.86
γ 46.0	41.80	26.50	28.24	54.79

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 47.0	32.54	23.45	24.23	41.54
γ 48.0	26.63	20.78	21.41	32.29
γ 49.0	23.66	18.32	18.84	26.00
γ 50.0	21.13	16.17	16.75	22.82
γ 51.0	18.82	13.77	14.98	20.30
γ 52.0	16.75	12.42	13.07	18.01
γ 53.0	14.32	11.37	11.84	16.19
γ 54.0	13.05	10.50	10.87	13.90
γ 55.0	12.03	9.73	9.99	12.40
γ 56.0	11.18	9.03	9.22	11.40
γ 57.0	10.42	8.38	8.56	10.54
γ 58.0	9.73	7.82	7.94	9.80
γ 59.0	9.07	7.33	7.39	9.17
γ 60.0	8.49	6.92	6.97	8.64
γ 61.0	8.02	6.55	6.60	8.14
γ 62.0	7.61	6.18	6.26	7.65
γ 63.0	7.25	5.87	5.93	7.25
γ 64.0	6.92	5.58	5.65	6.91
γ 65.0	6.61	5.30	5.42	6.60
γ 66.0	6.33	5.07	5.24	6.30
γ 67.0	6.05	4.84	5.08	6.04
γ 68.0	5.81	4.64	4.93	5.80
γ 69.0	5.58	4.45	4.78	5.60
γ 70.0	5.36	4.26	4.65	5.42
γ 71.0	5.16	4.09	4.51	5.25
γ 72.0	4.97	3.94	4.37	5.09
γ 73.0	4.78	3.78	4.22	4.94
γ 74.0	4.60	3.64	4.09	4.80
γ 75.0	4.44	3.50	3.95	4.65
γ 76.0	4.26	3.36	3.82	4.51
γ 77.0	4.09	3.23	3.68	4.37
γ 78.0	3.93	3.11	3.53	4.23
γ 79.0	3.79	3.01	3.39	4.09
γ 80.0	3.64	2.89	3.27	3.95
γ 81.0	3.50	2.78	3.16	3.82
γ 82.0	3.37	2.66	3.04	3.69
γ 83.0	3.23	2.55	2.91	3.56
γ 84.0	3.12	2.42	2.80	3.43
γ 85.0	2.98	2.26	2.67	3.28
γ 86.0	2.86	2.10	2.51	3.16
γ 87.0	2.73	1.88	2.35	3.02
γ 88.0	2.59	1.71	2.08	2.88
γ 89.0	2.39	1.63	1.80	2.71
γ 90.0	2.22	1.58	1.68	2.48
γ 91.0	2.14	1.55	1.65	2.32
γ 92.0	2.09	1.51	1.61	2.22
γ 93.0	2.04	1.49	1.56	2.16

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 94.0	1.99	1.44	1.52	2.10
γ 95.0	1.95	1.41	1.48	2.04
γ 96.0	1.91	1.39	1.45	1.98
γ 97.0	1.86	1.38	1.42	1.94
γ 98.0	1.83	1.35	1.39	1.88
γ 99.0	1.79	1.32	1.37	1.84
γ 100.0	1.76	1.31	1.35	1.81
γ 101.0	1.72	1.30	1.33	1.78
γ 102.0	1.71	1.28	1.32	1.74
γ 103.0	1.69	1.27	1.31	1.72
γ 104.0	1.66	1.27	1.30	1.69
γ 105.0	1.64	1.27	1.30	1.67
γ 106.0	1.64	1.26	1.29	1.66
γ 107.0	1.63	1.26	1.30	1.64
γ 108.0	1.62	1.27	1.30	1.62
γ 109.0	1.61	1.27	1.30	1.62
γ 110.0	1.60	1.27	1.31	1.61
γ 111.0	1.59	1.27	1.31	1.60
γ 112.0	1.59	1.27	1.33	1.61
γ 113.0	1.59	1.28	1.34	1.60
γ 114.0	1.58	1.28	1.35	1.62
γ 115.0	1.58	1.29	1.37	1.62
γ 116.0	1.57	1.28	1.39	1.61
γ 117.0	1.57	1.30	1.41	1.63
γ 118.0	1.56	1.31	1.42	1.63
γ 119.0	1.57	1.32	1.45	1.64
γ 120.0	1.57	1.33	1.46	1.66
γ 121.0	1.58	1.34	1.49	1.67
γ 122.0	1.59	1.36	1.51	1.69
γ 123.0	1.60	1.39	1.54	1.70
γ 124.0	1.61	1.42	1.56	1.73
γ 125.0	1.62	1.45	1.61	1.74
γ 126.0	1.65	1.48	1.64	1.76
γ 127.0	1.67	1.52	1.67	1.78
γ 128.0	1.70	1.56	1.71	1.81
γ 129.0	1.73	1.59	1.75	1.84
γ 130.0	1.77	1.64	1.79	1.87
γ 131.0	1.80	1.69	1.86	1.90
γ 132.0	1.84	1.74	1.91	1.94
γ 133.0	1.88	1.80	1.96	1.98
γ 134.0	1.92	1.86	2.02	2.02
γ 135.0	1.98	1.92	2.10	2.06
γ 136.0	2.03	2.00	2.16	2.13
γ 137.0	2.09	2.06	2.23	2.20
γ 138.0	2.16	2.13	2.31	2.26
γ 139.0	2.22	2.21	2.38	2.32
γ 140.0	2.30	2.28	2.47	2.39

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 141.0	2.35	2.36	2.55	2.47
γ 142.0	2.43	2.43	2.63	2.54
γ 143.0	2.50	2.51	2.70	2.61
γ 144.0	2.58	2.57	2.76	2.69
γ 145.0	2.64	2.64	2.83	2.75
γ 146.0	2.70	2.71	2.90	2.83
γ 147.0	2.77	2.78	2.95	2.89
γ 148.0	2.84	2.84	3.00	2.96
γ 149.0	2.90	2.89	3.06	3.00
γ 150.0	2.96	2.94	3.11	3.07
γ 151.0	3.01	2.99	3.15	3.12
γ 152.0	3.07	3.04	3.20	3.16
γ 153.0	3.12	3.08	3.25	3.20
γ 154.0	3.16	3.12	3.28	3.24
γ 155.0	3.22	3.16	3.32	3.29
γ 156.0	3.26	3.20	3.37	3.32
γ 157.0	3.30	3.24	3.40	3.36
γ 158.0	3.35	3.27	3.44	3.39
γ 159.0	3.39	3.31	3.48	3.42
γ 160.0	3.43	3.35	3.51	3.45
γ 161.0	3.46	3.39	3.54	3.48
γ 162.0	3.49	3.42	3.56	3.51
γ 163.0	3.54	3.46	3.59	3.54
γ 164.0	3.58	3.49	3.62	3.57
γ 165.0	3.61	3.53	3.65	3.59
γ 166.0	3.63	3.56	3.67	3.62
γ 167.0	3.66	3.59	3.69	3.65
γ 168.0	3.69	3.61	3.70	3.68
γ 169.0	3.71	3.63	3.71	3.70
γ 170.0	3.74	3.65	3.73	3.72
γ 171.0	3.75	3.66	3.75	3.73
γ 172.0	3.77	3.67	3.75	3.74
γ 173.0	3.78	3.68	3.75	3.76
γ 174.0	3.78	3.69	3.77	3.77
γ 175.0	3.79	3.69	3.76	3.78
γ 176.0	3.79	3.70	3.76	3.80
γ 177.0	3.80	3.71	3.76	3.80
γ 178.0	3.80	3.72	3.77	3.80
γ 179.0	3.80	3.73	3.78	3.81
γ 180.0	3.78	3.78	3.78	3.78