



Indoor Luminaire Photometric Data

Character Parameter

Lamp Speciality Parameter		Luminaire Speciality Parameter	
Rated Flux(lm):	472.000	Luminary Flux(lm):	495.099
Rated Power(W):		Luminary Efficiency:	104.89%
Rated Voltage(V):		Luminary EER(lm/W):	84.705
Tested Power(W):	5.845	Max. Candela(cd):	1019.270
Lamps' Inside:	1	Max Cand@Ang. (°):	C=0.0 γ=2.0
Tested Electrics(V, A, pf):	240.4, 0.028, 0.857	Beam Angle(50%Imax):	23.5(°)
Lamp Size(W*L*H):	0.050m*0.000m*0.000m	Left=-10.4°, Right=13.1°	IRF(%):
			449.055




2D Plane Light Intensity Distribution Curve

Test Machine:GON-2000


Test Date: 2018/03/06

C Plane Distribution Diagram



3D Light Intensity Distribution Modal

3D Light Intensity Distribution Modal



Curves: 3D Model — Fixture — Vert. HUD — Hori. HUD —
View Angles: Orient:0 Tilt:0 Roll:0 Spin:0

EQUIVALENT • IES Indoor Report
Photometric Filename:KA6R28BC.IES

Zonal Flux Tabulation

Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
0.0-1.0	0.95	0.95	0.20	0.20	47.0-48.0	2.45	450.53	0.52	95.45
1.0-2.0	2.79	3.73	0.59	0.79	48.0-49.0	2.16	452.70	0.46	95.91
2.0-3.0	4.51	8.25	0.96	1.75	49.0-50.0	1.95	454.65	0.41	96.32
3.0-4.0	6.07	14.31	1.29	3.03	50.0-51.0	1.78	456.43	0.38	96.70
4.0-5.0	7.40	21.71	1.57	4.60	51.0-52.0	1.64	458.07	0.35	97.05
5.0-6.0	8.49	30.20	1.80	6.40	52.0-53.0	1.50	459.57	0.32	97.37
6.0-7.0	9.39	39.59	1.99	8.39	53.0-54.0	1.39	460.96	0.29	97.66
7.0-8.0	10.10	49.69	2.14	10.53	54.0-55.0	1.28	462.24	0.27	97.93
8.0-9.0	10.66	60.34	2.26	12.78	55.0-56.0	1.20	463.44	0.25	98.19
9.0-10.0	11.09	71.44	2.35	15.13	56.0-57.0	1.12	464.56	0.24	98.42
10.0-11.0	11.43	82.87	2.42	17.56	57.0-58.0	1.05	465.61	0.22	98.65
11.0-12.0	11.71	94.58	2.48	20.04	58.0-59.0	0.99	466.60	0.21	98.86
12.0-13.0	11.93	106.51	2.53	22.57	59.0-60.0	0.93	467.53	0.20	99.05
13.0-14.0	12.11	118.62	2.57	25.13	60.0-61.0	0.88	468.42	0.19	99.24
14.0-15.0	12.24	130.86	2.59	27.73	61.0-62.0	0.84	469.26	0.18	99.42
15.0-16.0	12.36	143.23	2.62	30.34	62.0-63.0	0.80	470.06	0.17	99.59
16.0-17.0	12.45	155.68	2.64	32.98	63.0-64.0	0.77	470.83	0.16	99.75
17.0-18.0	12.49	168.17	2.65	35.63	64.0-65.0	0.73	471.57	0.16	99.91
18.0-19.0	12.49	180.66	2.65	38.28	65.0-66.0	0.70	472.27	0.15	100.06
19.0-20.0	12.45	193.11	2.64	40.91	66.0-67.0	0.67	472.93	0.14	100.20
20.0-21.0	12.36	205.47	2.62	43.53	67.0-68.0	0.63	473.57	0.13	100.33
21.0-22.0	12.23	217.70	2.59	46.12	68.0-69.0	0.60	474.17	0.13	100.46
22.0-23.0	12.10	229.80	2.56	48.69	69.0-70.0	0.57	474.74	0.12	100.58
23.0-24.0	11.96	241.76	2.53	51.22	70.0-71.0	0.55	475.29	0.12	100.70
24.0-25.0	11.79	253.55	2.50	53.72	71.0-72.0	0.53	475.82	0.11	100.81
25.0-26.0	11.59	265.14	2.46	56.17	72.0-73.0	0.51	476.33	0.11	100.92
26.0-27.0	11.39	276.53	2.41	58.59	73.0-74.0	0.49	476.82	0.10	101.02
27.0-28.0	11.18	287.71	2.37	60.96	74.0-75.0	0.47	477.29	0.10	101.12
28.0-29.0	10.98	298.69	2.33	63.28	75.0-76.0	0.46	477.75	0.10	101.22
29.0-30.0	10.80	309.48	2.29	65.57	76.0-77.0	0.44	478.19	0.09	101.31
30.0-31.0	10.63	320.12	2.25	67.82	77.0-78.0	0.43	478.62	0.09	101.40
31.0-32.0	10.48	330.60	2.22	70.04	78.0-79.0	0.41	479.03	0.09	101.49
32.0-33.0	10.35	340.95	2.19	72.24	79.0-80.0	0.40	479.43	0.08	101.57
33.0-34.0	10.27	351.22	2.17	74.41	80.0-81.0	0.38	479.81	0.08	101.65
34.0-35.0	10.21	361.43	2.16	76.57	81.0-82.0	0.37	480.18	0.08	101.73
35.0-36.0	10.17	371.60	2.16	78.73	82.0-83.0	0.35	480.53	0.07	101.81
36.0-37.0	10.11	381.71	2.14	80.87	83.0-84.0	0.34	480.87	0.07	101.88
37.0-38.0	9.96	391.67	2.11	82.98	84.0-85.0	0.32	481.19	0.07	101.95
38.0-39.0	9.61	401.28	2.04	85.02	85.0-86.0	0.31	481.50	0.06	102.01
39.0-40.0	9.03	410.31	1.91	86.93	86.0-87.0	0.29	481.78	0.06	102.07
40.0-41.0	8.23	418.54	1.74	88.67	87.0-88.0	0.27	482.05	0.06	102.13
41.0-42.0	7.30	425.84	1.55	90.22	88.0-89.0	0.25	482.31	0.05	102.18
42.0-43.0	6.29	432.13	1.33	91.55	89.0-90.0	0.24	482.54	0.05	102.23
43.0-44.0	5.26	437.39	1.11	92.67	90.0-91.0	0.22	482.76	0.05	102.28
44.0-45.0	4.30	441.68	0.91	93.58	91.0-92.0	0.21	482.98	0.04	102.33
45.0-46.0	3.50	445.19	0.74	94.32	92.0-93.0	0.21	483.18	0.04	102.37
46.0-47.0	2.89	448.08	0.61	94.93	93.0-94.0	0.20	483.38	0.04	102.41


EQUIVALENT • IES Indoor Report

Photometric Filename:KA6R28BC.IES

Zonal Flux Tabulation - (Cont.)


Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
94.0-95.0	0.19	483.57	0.04	102.45	141.0-142.0	0.17	490.99	0.04	104.02
95.0-96.0	0.19	483.76	0.04	102.49	142.0-143.0	0.17	491.15	0.04	104.06
96.0-97.0	0.19	483.95	0.04	102.53	143.0-144.0	0.17	491.32	0.04	104.09
97.0-98.0	0.18	484.13	0.04	102.57	144.0-145.0	0.17	491.49	0.04	104.13
98.0-99.0	0.18	484.31	0.04	102.61	145.0-146.0	0.17	491.66	0.04	104.16
99.0-100.0	0.17	484.48	0.04	102.64	146.0-147.0	0.17	491.82	0.04	104.20
100.0-101.0	0.17	484.65	0.04	102.68	147.0-148.0	0.16	491.99	0.03	104.23
101.0-102.0	0.17	484.82	0.04	102.72	148.0-149.0	0.16	492.15	0.03	104.27
102.0-103.0	0.16	484.98	0.03	102.75	149.0-150.0	0.16	492.31	0.03	104.30
103.0-104.0	0.16	485.15	0.03	102.79	150.0-151.0	0.16	492.47	0.03	104.34
104.0-105.0	0.16	485.31	0.03	102.82	151.0-152.0	0.16	492.63	0.03	104.37
105.0-106.0	0.16	485.46	0.03	102.85	152.0-153.0	0.15	492.78	0.03	104.40
106.0-107.0	0.16	485.62	0.03	102.89	153.0-154.0	0.15	492.93	0.03	104.43
107.0-108.0	0.15	485.77	0.03	102.92	154.0-155.0	0.15	493.08	0.03	104.47
108.0-109.0	0.15	485.93	0.03	102.95	155.0-156.0	0.14	493.22	0.03	104.50
109.0-110.0	0.15	486.08	0.03	102.98	156.0-157.0	0.14	493.36	0.03	104.53
110.0-111.0	0.15	486.23	0.03	103.01	157.0-158.0	0.14	493.50	0.03	104.55
111.0-112.0	0.15	486.38	0.03	103.05	158.0-159.0	0.13	493.63	0.03	104.58
112.0-113.0	0.15	486.53	0.03	103.08	159.0-160.0	0.13	493.76	0.03	104.61
113.0-114.0	0.15	486.67	0.03	103.11	160.0-161.0	0.12	493.88	0.03	104.64
114.0-115.0	0.15	486.82	0.03	103.14	161.0-162.0	0.12	494.00	0.03	104.66
115.0-116.0	0.15	486.97	0.03	103.17	162.0-163.0	0.11	494.11	0.02	104.68
116.0-117.0	0.15	487.12	0.03	103.20	163.0-164.0	0.11	494.22	0.02	104.71
117.0-118.0	0.15	487.26	0.03	103.23	164.0-165.0	0.10	494.32	0.02	104.73
118.0-119.0	0.15	487.41	0.03	103.26	165.0-166.0	0.10	494.42	0.02	104.75
119.0-120.0	0.15	487.55	0.03	103.30	166.0-167.0	0.09	494.51	0.02	104.77
120.0-121.0	0.15	487.70	0.03	103.33	167.0-168.0	0.09	494.59	0.02	104.79
121.0-122.0	0.15	487.85	0.03	103.36	168.0-169.0	0.08	494.67	0.02	104.80
122.0-123.0	0.15	488.00	0.03	103.39	169.0-170.0	0.07	494.74	0.02	104.82
123.0-124.0	0.15	488.14	0.03	103.42	170.0-171.0	0.07	494.81	0.01	104.83
124.0-125.0	0.15	488.29	0.03	103.45	171.0-172.0	0.06	494.87	0.01	104.85
125.0-126.0	0.15	488.44	0.03	103.48	172.0-173.0	0.05	494.92	0.01	104.86
126.0-127.0	0.15	488.59	0.03	103.52	173.0-174.0	0.05	494.97	0.01	104.87
127.0-128.0	0.15	488.74	0.03	103.55	174.0-175.0	0.04	495.01	0.01	104.87
128.0-129.0	0.15	488.90	0.03	103.58	175.0-176.0	0.03	495.04	0.01	104.88
129.0-130.0	0.15	489.05	0.03	103.61	176.0-177.0	0.03	495.07	0.01	104.89
130.0-131.0	0.15	489.20	0.03	103.65	177.0-178.0	0.02	495.08	0.00	104.89
131.0-132.0	0.16	489.36	0.03	103.68	178.0-179.0	0.01	495.10	0.00	104.89
132.0-133.0	0.16	489.52	0.03	103.71	179.0-180.0	0.00	495.10	0.00	104.89
133.0-134.0	0.16	489.68	0.03	103.74					
134.0-135.0	0.16	489.84	0.03	103.78					
135.0-136.0	0.16	490.00	0.03	103.81					
136.0-137.0	0.16	490.16	0.03	103.85					
137.0-138.0	0.16	490.32	0.03	103.88					
138.0-139.0	0.16	490.49	0.03	103.92					
139.0-140.0	0.17	490.65	0.04	103.95					
140.0-141.0	0.17	490.82	0.04	103.99					

Rectangle ISO Lighting Intensity Diagram



Plane ISO-Illuminance Diagram

Plane ISO-Illuminance Curve



Curves:

unit:lx

[EMax] =113.045

— [EMax*90%]=101.741

— [EMax*80%]=90.436

— [EMax*70%]=79.132

— [EMax*60%]=67.827

— [EMax*50%]=56.523

— [EMax*40%]=45.218

— [EMax*30%]=33.914

— [EMax*20%]=22.609

— [EMax*10%]=11.305


Working Plane Luminaire Mounting Height(m): 3.00

Working Plane Maximum Illuminance(lx): 113.05

Working Plane Maximum Illuminance Position(d/h):H0.0 V0.0


3D Plane ISO Illuminance Diagram

3D Plane Illuminance Modal



Space ISO Illuminance Diagram

Space ISO Illuminance Curve



Curves:

[Unit: lx]


[EMax] =1017.408

- [EMax*90%]=915.668
- [EMax*80%]=813.927
- [EMax*70%]=712.186
- [EMax*60%]=610.445
- [EMax*50%]=508.704
- [EMax*40%]=406.963
- [EMax*30%]=305.223
- [EMax*20%]=203.482
- [EMax*10%]=101.741

Space Plane Maximum Illuminance and @Angle:1017.41lx,2.0deg
Plane Maximum Lighting Intensity and @Angle:1019.270cd,0deg

Illuminance-Distance Diagram

Illuminance-Distance Curve



Indoor Luminance Limiting Curves


Glare Grade Table

GI	Quality	Using Illuminance							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table


Gama (deg)	45	50	55	60	65	70	75	80	85
C0	40759	21280	14611	11453	10455	9497	10112	12251	19915
C90	20312	12728	9686	8333	7660	7109	7550	8901	13574

Luminance Limiting Curve



Luminous Size: Length(m)=0.000 Width(m)=-0.050 Height(m)=0.000 Area(m^2)=0.001963
 Luminous Type: Without Luminous Side
 Luminous Curves: C0-C180 Color: — C90-C270 Color: —

Indoor Budgetary Estimate Table



Indoor Coefficient of Utilization Table

Coefficients of Utilization – Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC (%)	80				70				50			30			10			0
RhoW (%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization(%)																	
0	124	124	124	124	121	121	121	121	115	115	115	110	110	110	105	105	105	102
1	118	115	112	109	115	112	109	107	107	105	103	103	101	100	99	98	96	94
2	111	106	101	97	109	104	100	96	100	97	94	96	94	91	93	91	89	87
3	105	98	93	88	103	97	91	87	93	89	86	90	87	84	88	85	82	80
4	100	91	85	81	98	90	84	80	87	83	79	85	81	78	83	79	76	75
5	95	85	79	74	93	84	78	74	82	77	73	80	76	72	78	74	71	70
6	90	80	74	69	88	79	73	69	77	72	68	75	71	67	74	70	67	65
7	85	75	69	64	84	74	68	64	73	67	63	71	66	63	70	66	62	61
8	81	71	65	60	80	70	64	60	69	63	59	68	63	59	66	62	59	57
9	77	67	61	56	76	66	60	56	65	60	56	64	59	56	63	59	55	54
10	74	64	57	53	73	63	57	53	62	57	53	61	56	53	60	56	52	51

Unified Glare Rating Table

Unified Glare Rating Table

Ceiling RCC	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW	0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size	Vewed crosswise					Vewed endwise				
X=2H Y=2H	21.3	22.4	21.7	22.8	23.2	19.5	20.7	20.0	21.1	21.5
	21.3	22.4	21.8	22.8	23.2	19.6	20.7	20.0	21.0	21.5
	21.4	22.4	21.9	22.8	23.3	19.7	20.7	20.1	21.1	21.5
	21.5	22.5	22.0	22.9	23.3	19.8	20.7	20.2	21.1	21.6
	21.6	22.5	22.1	23.0	23.4	19.9	20.7	20.3	21.2	21.6
	21.8	22.6	22.3	23.1	23.6	20.0	20.8	20.5	21.3	21.7
X=4H Y=2H	21.1	22.1	21.6	22.5	22.9	19.4	20.4	19.9	20.8	21.2
	21.3	22.1	21.7	22.6	23.0	19.6	20.4	20.0	20.9	21.3
	21.4	22.2	21.9	22.7	23.2	19.7	20.5	20.2	21.0	21.5
	21.7	22.4	22.2	22.9	23.4	20.0	20.6	20.5	21.1	21.7
	21.9	22.5	22.4	23.0	23.5	20.1	20.8	20.6	21.3	21.8
	22.1	22.7	22.7	23.2	23.8	20.3	20.9	20.9	21.4	22.0
X=8H Y=4H	21.4	22.0	21.9	22.5	23.1	19.7	20.4	20.2	20.9	21.4
	21.8	22.3	22.3	22.9	23.5	20.1	20.6	20.6	21.2	21.8
	22.1	22.6	22.6	23.1	23.7	20.3	20.9	20.9	21.4	22.0
	22.5	23.0	23.0	23.5	24.1	20.7	21.2	21.3	21.7	22.3
X=12H Y=4H	21.4	22.0	21.9	22.5	23.0	19.7	20.3	20.2	20.8	21.4
	21.8	22.3	22.4	22.8	23.4	20.1	20.6	20.7	21.1	21.7
	22.1	22.6	22.7	23.2	23.8	20.4	20.9	21.0	21.5	22.1
Variations with the objerver position at spacings										
S=1.0H	0.1/-0.1					0.2/-0.2				
S=1.5H	0.2/-0.3					0.3/-0.4				
S=2.0H	0.4/-0.3					0.5/-0.4				
Reduced UGR Table:										
Nordic Standard Table:	BK0					BK0				
Correction Value	1.3					1.2				

o the CIE Pub.117, data has been corrected, refers to the lamp's lumens 8.2flm.

EQUIVALENT • IES Indoor Report

Photometric Filename:KA6R28BC.IES

Candela Tabulation

V/H	C0.0	C90.0	C180.0	C270.0
γ 0.0	992.73	992.73	992.73	992.73
γ 1.0	1016.50	946.70	960.56	1007.23
γ 2.0	1019.27	897.13	909.49	1014.03
γ 3.0	1008.91	841.13	850.39	1009.75
γ 4.0	978.36	784.66	788.95	987.86
γ 5.0	931.50	728.01	729.28	948.09
γ 6.0	876.56	679.02	672.16	899.97
γ 7.0	817.91	635.97	623.34	843.76
γ 8.0	759.20	595.56	582.45	784.24
γ 9.0	703.58	559.30	548.34	726.29
γ 10.0	647.50	526.34	519.45	672.92
γ 11.0	595.25	496.39	492.26	627.29
γ 12.0	550.66	471.02	469.08	581.95
γ 13.0	513.02	447.76	447.08	541.64
γ 14.0	479.97	423.19	425.78	505.43
γ 15.0	450.74	400.53	406.16	475.78
γ 16.0	424.95	380.43	387.08	449.38
γ 17.0	400.59	361.12	368.08	426.55
γ 18.0	380.21	340.06	350.03	404.60
γ 19.0	362.14	320.34	331.51	383.16
γ 20.0	343.09	302.43	313.96	363.54
γ 21.0	323.45	286.06	297.46	343.83
γ 22.0	308.10	269.99	281.36	324.39
γ 23.0	295.44	255.30	264.81	307.55
γ 24.0	281.24	242.02	250.06	291.98
γ 25.0	268.76	228.73	236.02	275.38
γ 26.0	255.39	214.81	222.46	262.57
γ 27.0	242.43	205.23	209.60	249.37
γ 28.0	229.67	194.53	199.68	236.09
γ 29.0	216.31	185.29	192.54	224.30
γ 30.0	207.58	176.92	183.87	212.51
γ 31.0	198.15	167.93	177.23	204.34
γ 32.0	190.19	162.11	169.06	194.27
γ 33.0	182.01	157.83	164.04	186.11
γ 34.0	174.71	155.14	159.49	177.57
γ 35.0	169.60	153.20	155.40	169.87
γ 36.0	165.54	149.09	150.70	164.49
γ 37.0	163.09	141.22	145.74	160.62
γ 38.0	159.21	127.55	138.72	157.01
γ 39.0	151.08	112.63	126.21	154.01
γ 40.0	138.05	95.53	109.75	148.35
γ 41.0	122.04	77.65	94.14	138.58
γ 42.0	106.30	60.96	78.43	125.30
γ 43.0	89.64	45.48	62.66	110.83
γ 44.0	71.91	35.09	48.09	93.61
γ 45.0	56.59	28.20	36.85	76.87
γ 46.0	45.12	24.68	29.31	60.67

EQUIVALENT • IES Indoor Report
Photometric Filename:KA6R28BC.IES

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 47.0	37.29	22.17	25.10	46.29
γ 48.0	32.83	20.08	22.51	36.63
γ 49.0	29.72	18.09	20.45	30.56
γ 50.0	26.86	16.06	18.18	27.35
γ 51.0	24.54	14.57	15.97	24.92
γ 52.0	22.08	13.43	14.12	22.90
γ 53.0	19.69	12.50	12.83	20.74
γ 54.0	17.91	11.67	11.76	18.64
γ 55.0	16.45	10.91	10.85	16.85
γ 56.0	15.16	10.31	10.00	15.48
γ 57.0	13.93	9.65	9.28	14.30
γ 58.0	12.96	9.04	8.59	13.17
γ 59.0	12.13	8.56	7.95	12.19
γ 60.0	11.24	8.18	7.43	11.36
γ 61.0	10.61	7.81	6.96	10.51
γ 62.0	10.09	7.57	6.57	9.74
γ 63.0	9.57	7.17	6.25	9.13
γ 64.0	9.08	6.90	5.98	8.61
γ 65.0	8.68	6.36	5.69	8.11
γ 66.0	8.17	6.04	5.37	7.74
γ 67.0	7.76	5.53	5.12	7.33
γ 68.0	7.26	5.21	4.77	7.07
γ 69.0	6.83	4.99	4.50	6.61
γ 70.0	6.38	4.77	4.33	6.26
γ 71.0	6.06	4.57	4.18	5.96
γ 72.0	5.81	4.37	4.04	5.59
γ 73.0	5.56	4.19	3.90	5.38
γ 74.0	5.34	4.00	3.77	5.18
γ 75.0	5.14	3.84	3.65	5.01
γ 76.0	4.93	3.67	3.52	4.84
γ 77.0	4.74	3.50	3.38	4.68
γ 78.0	4.54	3.33	3.25	4.52
γ 79.0	4.36	3.17	3.12	4.36
γ 80.0	4.18	3.04	2.99	4.19
γ 81.0	4.01	2.89	2.87	4.03
γ 82.0	3.84	2.77	2.73	3.88
γ 83.0	3.69	2.65	2.61	3.72
γ 84.0	3.54	2.49	2.49	3.57
γ 85.0	3.41	2.32	2.37	3.43
γ 86.0	3.25	2.11	2.26	3.29
γ 87.0	3.08	1.83	2.11	3.16
γ 88.0	2.93	1.67	1.91	3.02
γ 89.0	2.68	1.63	1.76	2.87
γ 90.0	2.38	1.59	1.72	2.59
γ 91.0	2.23	1.55	1.67	2.40
γ 92.0	2.17	1.52	1.63	2.28
γ 93.0	2.11	1.48	1.59	2.21

EQUIVALENT • IES Indoor Report
Photometric Filename:KA6R28BC.IES

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 94.0	2.06	1.44	1.55	2.15
γ 95.0	2.01	1.42	1.52	2.10
γ 96.0	1.97	1.39	1.48	2.04
γ 97.0	1.92	1.37	1.46	1.99
γ 98.0	1.88	1.34	1.43	1.95
γ 99.0	1.84	1.32	1.40	1.90
γ 100.0	1.81	1.31	1.39	1.87
γ 101.0	1.78	1.29	1.38	1.83
γ 102.0	1.75	1.28	1.36	1.80
γ 103.0	1.72	1.27	1.35	1.77
γ 104.0	1.69	1.25	1.34	1.73
γ 105.0	1.68	1.26	1.34	1.72
γ 106.0	1.66	1.26	1.34	1.70
γ 107.0	1.64	1.25	1.34	1.68
γ 108.0	1.64	1.26	1.34	1.66
γ 109.0	1.62	1.26	1.34	1.65
γ 110.0	1.61	1.26	1.34	1.64
γ 111.0	1.60	1.27	1.35	1.63
γ 112.0	1.60	1.27	1.36	1.63
γ 113.0	1.59	1.29	1.38	1.63
γ 114.0	1.59	1.29	1.39	1.62
γ 115.0	1.59	1.29	1.41	1.63
γ 116.0	1.59	1.32	1.42	1.63
γ 117.0	1.59	1.33	1.44	1.63
γ 118.0	1.59	1.34	1.46	1.65
γ 119.0	1.60	1.36	1.48	1.65
γ 120.0	1.60	1.38	1.51	1.67
γ 121.0	1.62	1.41	1.54	1.68
γ 122.0	1.63	1.43	1.56	1.71
γ 123.0	1.64	1.46	1.60	1.72
γ 124.0	1.66	1.49	1.63	1.75
γ 125.0	1.69	1.53	1.66	1.76
γ 126.0	1.71	1.57	1.70	1.79
γ 127.0	1.73	1.60	1.73	1.82
γ 128.0	1.77	1.65	1.77	1.85
γ 129.0	1.80	1.69	1.82	1.88
γ 130.0	1.83	1.73	1.87	1.91
γ 131.0	1.86	1.78	1.92	1.94
γ 132.0	1.90	1.84	1.96	1.98
γ 133.0	1.94	1.88	2.02	2.03
γ 134.0	1.99	1.94	2.07	2.07
γ 135.0	2.03	2.00	2.13	2.11
γ 136.0	2.08	2.06	2.18	2.16
γ 137.0	2.13	2.11	2.25	2.21
γ 138.0	2.19	2.17	2.32	2.27
γ 139.0	2.23	2.23	2.40	2.32
γ 140.0	2.29	2.30	2.46	2.38

EQUIVALENT • IES Indoor Report
Photometric Filename:KA6R28BC.IES

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 141.0	2.36	2.36	2.53	2.45
γ 142.0	2.42	2.42	2.58	2.50
γ 143.0	2.47	2.49	2.65	2.57
γ 144.0	2.53	2.54	2.71	2.63
γ 145.0	2.59	2.61	2.77	2.68
γ 146.0	2.64	2.66	2.81	2.74
γ 147.0	2.69	2.72	2.87	2.78
γ 148.0	2.75	2.76	2.93	2.84
γ 149.0	2.80	2.81	2.96	2.89
γ 150.0	2.86	2.86	3.01	2.94
γ 151.0	2.91	2.92	3.05	2.98
γ 152.0	2.96	2.95	3.10	3.03
γ 153.0	3.01	2.99	3.14	3.08
γ 154.0	3.06	3.04	3.18	3.11
γ 155.0	3.10	3.07	3.23	3.14
γ 156.0	3.14	3.12	3.26	3.20
γ 157.0	3.19	3.16	3.30	3.23
γ 158.0	3.23	3.20	3.35	3.27
γ 159.0	3.27	3.24	3.38	3.31
γ 160.0	3.31	3.28	3.42	3.35
γ 161.0	3.36	3.32	3.45	3.37
γ 162.0	3.39	3.36	3.48	3.41
γ 163.0	3.43	3.39	3.52	3.44
γ 164.0	3.46	3.42	3.54	3.47
γ 165.0	3.50	3.46	3.57	3.51
γ 166.0	3.54	3.50	3.59	3.53
γ 167.0	3.57	3.52	3.62	3.56
γ 168.0	3.60	3.56	3.64	3.59
γ 169.0	3.63	3.58	3.66	3.62
γ 170.0	3.66	3.60	3.69	3.65
γ 171.0	3.69	3.63	3.70	3.67
γ 172.0	3.72	3.65	3.71	3.69
γ 173.0	3.74	3.66	3.73	3.71
γ 174.0	3.77	3.68	3.74	3.74
γ 175.0	3.78	3.69	3.74	3.76
γ 176.0	3.79	3.70	3.76	3.77
γ 177.0	3.79	3.71	3.77	3.79
γ 178.0	3.80	3.72	3.77	3.80
γ 179.0	3.81	3.72	3.79	3.80
γ 180.0	3.79	3.79	3.79	3.79