




Indoor Luminaire Photometric Data

Character Parameter

Lamp Speciality Parameter		Luminaire Speciality Parameter	
Rated Flux(lm):	809.000	Luminary Flux(lm):	888.841
Rated Power(W):		Luminary Efficiency:	109.87%
Rated Voltage(V):		Luminary EER(lm/W):	101.885
Tested Power(W):	8.724	Max. Candela(cd):	1803.764
Lamps' Inside:	1	Max Cand@Ang. (°):	C=0.0 γ=2.0
Tested Electrics(V, A, pf):	240.2, 0.040, 0.902	Beam Angle(50%Imax):	36.5(°)
Lamp Size(W*L*H):	0.050m*0.000m*0.000m	Left=-16.6°, Right=19.9°	IRF(%):
			421.304




2D Plane Light Intensity Distribution Curve



3D Light Intensity Distribution Modal

3D Light Intensity Distribution Modal



Curves: 3D Model — Fixture — Vert. HUD — Hori. HUD —
View Angles: Orient:0 Tilt:0 Roll:0 Spin:0


Zonal Flux Tabulation

Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
0.0-1.0	1.71	1.71	0.21	0.21	47.0-48.0	3.75	827.39	0.46	102.27
1.0-2.0	5.13	6.84	0.63	0.85	48.0-49.0	3.52	830.92	0.44	102.71
2.0-3.0	8.49	15.33	1.05	1.89	49.0-50.0	3.32	834.24	0.41	103.12
3.0-4.0	11.77	27.10	1.45	3.35	50.0-51.0	3.13	837.36	0.39	103.51
4.0-5.0	14.93	42.02	1.85	5.19	51.0-52.0	2.95	840.31	0.36	103.87
5.0-6.0	17.93	59.95	2.22	7.41	52.0-53.0	2.78	843.10	0.34	104.21
6.0-7.0	20.72	80.67	2.56	9.97	53.0-54.0	2.63	845.72	0.32	104.54
7.0-8.0	23.30	103.97	2.88	12.85	54.0-55.0	2.48	848.20	0.31	104.85
8.0-9.0	25.61	129.58	3.17	16.02	55.0-56.0	2.34	850.54	0.29	105.13
9.0-10.0	27.63	157.21	3.42	19.43	56.0-57.0	2.20	852.74	0.27	105.41
10.0-11.0	29.35	186.56	3.63	23.06	57.0-58.0	2.07	854.81	0.26	105.66
11.0-12.0	30.71	217.27	3.80	26.86	58.0-59.0	1.95	856.76	0.24	105.90
12.0-13.0	31.71	248.99	3.92	30.78	59.0-60.0	1.83	858.60	0.23	106.13
13.0-14.0	32.35	281.33	4.00	34.78	60.0-61.0	1.72	860.32	0.21	106.34
14.0-15.0	32.61	313.95	4.03	38.81	61.0-62.0	1.61	861.93	0.20	106.54
15.0-16.0	32.55	346.50	4.02	42.83	62.0-63.0	1.51	863.44	0.19	106.73
16.0-17.0	32.20	378.70	3.98	46.81	63.0-64.0	1.40	864.84	0.17	106.90
17.0-18.0	31.58	410.29	3.90	50.72	64.0-65.0	1.30	866.14	0.16	107.06
18.0-19.0	30.73	441.02	3.80	54.51	65.0-66.0	1.21	867.35	0.15	107.21
19.0-20.0	29.68	470.70	3.67	58.18	66.0-67.0	1.11	868.46	0.14	107.35
20.0-21.0	28.46	499.16	3.52	61.70	67.0-68.0	1.03	869.49	0.13	107.48
21.0-22.0	27.11	526.27	3.35	65.05	68.0-69.0	0.95	870.44	0.12	107.59
22.0-23.0	25.67	551.93	3.17	68.22	69.0-70.0	0.87	871.31	0.11	107.70
23.0-24.0	24.16	576.09	2.99	71.21	70.0-71.0	0.80	872.11	0.10	107.80
24.0-25.0	22.61	598.70	2.79	74.00	71.0-72.0	0.74	872.85	0.09	107.89
25.0-26.0	21.09	619.79	2.61	76.61	72.0-73.0	0.68	873.52	0.08	107.98
26.0-27.0	19.60	639.38	2.42	79.03	73.0-74.0	0.62	874.14	0.08	108.05
27.0-28.0	18.14	657.53	2.24	81.28	74.0-75.0	0.56	874.70	0.07	108.12
28.0-29.0	16.75	674.28	2.07	83.35	75.0-76.0	0.51	875.21	0.06	108.18
29.0-30.0	15.44	689.72	1.91	85.26	76.0-77.0	0.46	875.67	0.06	108.24
30.0-31.0	14.21	703.93	1.76	87.01	77.0-78.0	0.41	876.08	0.05	108.29
31.0-32.0	13.06	716.99	1.61	88.63	78.0-79.0	0.37	876.45	0.05	108.34
32.0-33.0	11.98	728.97	1.48	90.11	79.0-80.0	0.34	876.80	0.04	108.38
33.0-34.0	10.98	739.95	1.36	91.47	80.0-81.0	0.32	877.11	0.04	108.42
34.0-35.0	10.06	750.02	1.24	92.71	81.0-82.0	0.30	877.41	0.04	108.46
35.0-36.0	9.21	759.23	1.14	93.85	82.0-83.0	0.28	877.69	0.03	108.49
36.0-37.0	8.44	767.67	1.04	94.89	83.0-84.0	0.26	877.96	0.03	108.52
37.0-38.0	7.74	775.41	0.96	95.85	84.0-85.0	0.25	878.20	0.03	108.55
38.0-39.0	7.12	782.54	0.88	96.73	85.0-86.0	0.23	878.43	0.03	108.58
39.0-40.0	6.56	789.10	0.81	97.54	86.0-87.0	0.21	878.64	0.03	108.61
40.0-41.0	6.07	795.16	0.75	98.29	87.0-88.0	0.20	878.84	0.02	108.63
41.0-42.0	5.62	800.79	0.70	98.98	88.0-89.0	0.18	879.02	0.02	108.65
42.0-43.0	5.22	806.01	0.65	99.63	89.0-90.0	0.16	879.18	0.02	108.67
43.0-44.0	4.86	810.87	0.60	100.23	90.0-91.0	0.15	879.33	0.02	108.69
44.0-45.0	4.54	815.41	0.56	100.79	91.0-92.0	0.14	879.46	0.02	108.71
45.0-46.0	4.25	819.66	0.53	101.32	92.0-93.0	0.13	879.59	0.02	108.73
46.0-47.0	3.99	823.65	0.49	101.81	93.0-94.0	0.12	879.72	0.01	108.74


Zonal Flux Tabulation - (Cont.)

Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone (γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
94.0-95.0	0.11	879.83	0.01	108.76	141.0-142.0	0.17	883.58	0.02	109.22
95.0-96.0	0.11	879.94	0.01	108.77	142.0-143.0	0.18	883.76	0.02	109.24
96.0-97.0	0.10	880.04	0.01	108.78	143.0-144.0	0.18	883.94	0.02	109.26
97.0-98.0	0.09	880.13	0.01	108.79	144.0-145.0	0.18	884.13	0.02	109.29
98.0-99.0	0.09	880.22	0.01	108.80	145.0-146.0	0.19	884.31	0.02	109.31
99.0-100.0	0.08	880.30	0.01	108.81	146.0-147.0	0.19	884.51	0.02	109.33
100.0-101.0	0.08	880.38	0.01	108.82	147.0-148.0	0.20	884.70	0.02	109.36
101.0-102.0	0.07	880.45	0.01	108.83	148.0-149.0	0.20	884.90	0.02	109.38
102.0-103.0	0.07	880.52	0.01	108.84	149.0-150.0	0.20	885.10	0.02	109.41
103.0-104.0	0.06	880.58	0.01	108.85	150.0-151.0	0.20	885.30	0.02	109.43
104.0-105.0	0.06	880.65	0.01	108.86	151.0-152.0	0.20	885.50	0.02	109.46
105.0-106.0	0.06	880.70	0.01	108.86	152.0-153.0	0.20	885.70	0.02	109.48
106.0-107.0	0.05	880.76	0.01	108.87	153.0-154.0	0.20	885.89	0.02	109.50
107.0-108.0	0.05	880.81	0.01	108.88	154.0-155.0	0.20	886.09	0.02	109.53
108.0-109.0	0.05	880.86	0.01	108.88	155.0-156.0	0.19	886.28	0.02	109.55
109.0-110.0	0.05	880.90	0.01	108.89	156.0-157.0	0.19	886.47	0.02	109.58
110.0-111.0	0.04	880.95	0.01	108.89	157.0-158.0	0.18	886.66	0.02	109.60
111.0-112.0	0.04	880.99	0.01	108.90	158.0-159.0	0.18	886.84	0.02	109.62
112.0-113.0	0.04	881.03	0.01	108.90	159.0-160.0	0.17	887.01	0.02	109.64
113.0-114.0	0.04	881.08	0.01	108.91	160.0-161.0	0.17	887.18	0.02	109.66
114.0-115.0	0.04	881.12	0.01	108.91	161.0-162.0	0.16	887.34	0.02	109.68
115.0-116.0	0.04	881.16	0.01	108.92	162.0-163.0	0.16	887.50	0.02	109.70
116.0-117.0	0.04	881.20	0.01	108.92	163.0-164.0	0.15	887.64	0.02	109.72
117.0-118.0	0.04	881.24	0.01	108.93	164.0-165.0	0.14	887.79	0.02	109.74
118.0-119.0	0.04	881.29	0.01	108.94	165.0-166.0	0.13	887.92	0.02	109.75
119.0-120.0	0.05	881.33	0.01	108.94	166.0-167.0	0.12	888.04	0.02	109.77
120.0-121.0	0.05	881.38	0.01	108.95	167.0-168.0	0.12	888.16	0.01	109.78
121.0-122.0	0.05	881.43	0.01	108.95	168.0-169.0	0.11	888.26	0.01	109.80
122.0-123.0	0.05	881.49	0.01	108.96	169.0-170.0	0.10	888.36	0.01	109.81
123.0-124.0	0.06	881.54	0.01	108.97	170.0-171.0	0.09	888.45	0.01	109.82
124.0-125.0	0.06	881.61	0.01	108.97	171.0-172.0	0.08	888.53	0.01	109.83
125.0-126.0	0.07	881.67	0.01	108.98	172.0-173.0	0.07	888.60	0.01	109.84
126.0-127.0	0.07	881.74	0.01	108.99	173.0-174.0	0.06	888.67	0.01	109.85
127.0-128.0	0.08	881.82	0.01	109.00	174.0-175.0	0.05	888.72	0.01	109.85
128.0-129.0	0.08	881.90	0.01	109.01	175.0-176.0	0.04	888.76	0.01	109.86
129.0-130.0	0.09	881.99	0.01	109.02	176.0-177.0	0.03	888.80	0.00	109.86
130.0-131.0	0.10	882.09	0.01	109.03	177.0-178.0	0.02	888.82	0.00	109.87
131.0-132.0	0.10	882.19	0.01	109.05	178.0-179.0	0.01	888.84	0.00	109.87
132.0-133.0	0.11	882.30	0.01	109.06	179.0-180.0	0.00	888.84	0.00	109.87
133.0-134.0	0.12	882.41	0.01	109.07					
134.0-135.0	0.12	882.53	0.02	109.09					
135.0-136.0	0.13	882.66	0.02	109.11					
136.0-137.0	0.14	882.80	0.02	109.12					
137.0-138.0	0.14	882.94	0.02	109.14					
138.0-139.0	0.15	883.09	0.02	109.16					
139.0-140.0	0.16	883.25	0.02	109.18					
140.0-141.0	0.16	883.42	0.02	109.20					

Rectangle ISO Lighting Intensity Diagram




Plane ISO-Illuminance Diagram




3D Plane ISO Illuminance Diagram


3D Plane Illuminance Modal



Space ISO Illuminance Diagram




Illuminance-Distance Diagram



Indoor Luminance Limiting Curves


Glare Grade Table									
GI	Quality	Using Illuminance							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table									
Gama (deg)	45	50	55	60	65	70	75	80	85
C0	48100	35592	27533	21926	17669	14251	12149	11040	16128
C90	48460	35606	27115	21061	16258	12228	9624	8092	11319



Luminous Size: Length(m)=0.000 Width(m)=-0.050 Height(m)=0.000 Area(m^2)=0.001963
Luminous Type: Without Luminous Side
Luminous Curves: C0-C180 Color: — C90-C270 Color: —

Indoor Budgetary Estimate Table



Indoor Coefficient of Utilization Table

Coefficients of Utilization - Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC (%)	80				70				50			30			10			0
RhoW (%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization(%)																	
0	131	131	131	131	127	127	127	127	121	121	121	116	116	116	111	111	111	109
1	125	122	119	116	122	119	117	114	114	112	111	110	109	107	106	105	104	102
2	119	113	109	106	116	111	108	104	108	105	102	104	102	99	101	99	97	95
3	113	106	101	97	111	105	100	96	102	98	94	99	96	93	96	94	91	90
4	108	100	94	90	106	99	94	89	96	92	88	94	90	87	92	89	86	84
5	103	95	89	84	101	93	88	84	91	87	83	90	85	82	88	84	81	80
6	99	90	83	79	97	89	83	79	87	82	78	85	81	78	84	80	77	75
7	95	85	79	75	93	84	79	74	83	78	74	81	77	74	80	76	73	72
8	91	81	75	71	89	80	75	71	79	74	70	78	73	70	77	73	70	68
9	87	77	71	67	86	77	71	67	76	71	67	75	70	67	74	69	66	65
10	84	74	68	64	83	73	68	64	73	67	64	72	67	64	71	67	63	62

Unified Glare Rating Table

Unified Glare Rating Table											
Ceiling RCC		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size		Vewed crosswise					Vewed endwise				
X=2H	Y=2H	20.5	21.6	20.8	22.0	22.3	20.4	21.5	20.8	21.9	22.2
	Y=3H	20.7	21.8	21.1	22.1	22.5	20.5	21.6	20.9	21.9	22.3
	Y=4H	20.8	21.8	21.2	22.1	22.6	20.6	21.6	21.0	21.9	22.3
	Y=6H	20.8	21.7	21.3	22.1	22.6	20.5	21.5	21.0	21.9	22.3
	Y=8H	20.8	21.7	21.3	22.1	22.6	20.5	21.4	21.0	21.8	22.3
	Y=12H	20.9	21.7	21.3	22.1	22.6	20.5	21.4	21.0	21.8	22.3
X=4H	Y=2H	20.4	21.4	20.9	21.8	22.2	20.3	21.3	20.8	21.7	22.1
	Y=3H	20.8	21.6	21.2	22.1	22.5	20.6	21.4	21.0	21.9	22.3
	Y=4H	20.9	21.7	21.4	22.1	22.6	20.7	21.4	21.1	21.9	22.4
	Y=6H	21.0	21.7	21.5	22.2	22.7	20.7	21.4	21.2	21.9	22.3
	Y=8H	21.1	21.7	21.6	22.2	22.7	20.7	21.4	21.2	21.8	22.3
	Y=12H	21.2	21.8	21.7	22.3	22.8	20.7	21.3	21.2	21.8	22.3
X=8H	Y=4H	20.8	21.5	21.3	22.0	22.5	20.6	21.3	21.1	21.7	22.2
	Y=6H	21.0	21.6	21.5	22.1	22.7	20.6	21.2	21.2	21.7	22.3
	Y=8H	21.1	21.7	21.6	22.2	22.7	20.7	21.2	21.2	21.8	22.3
	Y=12H	21.3	21.8	21.8	22.3	22.9	20.8	21.3	21.3	21.8	22.4
X=12H	Y=4H	20.8	21.4	21.3	21.9	22.4	20.5	21.1	21.0	21.6	22.1
	Y=6H	21.0	21.5	21.5	22.0	22.6	20.6	21.2	21.2	21.6	22.2
	Y=8H	21.1	21.6	21.6	22.1	22.7	20.7	21.2	21.2	21.7	22.3
Variations with the objerver position at spacings											
S=1.0H		0.3/-0.3					0.4/-0.4				
S=1.5H		0.7/-0.7					0.9/-0.9				
S=2.0H		1.3/-1.2					1.7/-1.6				
Reduced UGR Table:											
Nordic Standard Table:		BK0					BK0				
Correction Value		1.0					0.8				

o the CIE Pub.117, data has been corrected, refers to the lamp's lumens 8.2flm.

IES EQUIVALENT
Photometric Filename:KA9L36BN.IES

Candela Tabulation

V/H	C0.0	C90.0	C180.0	C270.0
γ 0.0	1793.13	1793.13	1793.13	1793.13
γ 1.0	1799.07	1794.04	1779.68	1785.33
γ 2.0	1803.76	1790.14	1760.58	1772.14
γ 3.0	1801.18	1781.59	1735.26	1752.40
γ 4.0	1791.70	1767.37	1707.94	1724.12
γ 5.0	1776.36	1747.67	1672.14	1691.57
γ 6.0	1754.12	1723.64	1626.81	1651.88
γ 7.0	1724.65	1692.21	1576.16	1605.23
γ 8.0	1688.32	1657.32	1523.15	1553.01
γ 9.0	1647.53	1615.98	1463.33	1491.40
γ 10.0	1598.91	1567.35	1401.28	1427.94
γ 11.0	1545.79	1513.22	1331.81	1361.81
γ 12.0	1486.02	1449.63	1259.11	1291.51
γ 13.0	1422.26	1384.73	1181.36	1215.01
γ 14.0	1354.70	1314.63	1101.56	1134.45
γ 15.0	1280.72	1237.71	1021.91	1056.51
γ 16.0	1203.63	1157.31	946.34	982.88
γ 17.0	1123.53	1079.05	870.78	907.90
γ 18.0	1044.96	1002.30	797.64	836.05
γ 19.0	968.32	926.49	726.52	763.43
γ 20.0	894.98	853.65	658.57	694.38
γ 21.0	821.98	781.48	595.93	628.30
γ 22.0	750.50	713.74	536.30	567.55
γ 23.0	683.49	649.66	481.74	509.63
γ 24.0	618.93	588.53	430.82	456.44
γ 25.0	558.94	531.82	384.15	407.80
γ 26.0	504.06	479.76	342.65	364.20
γ 27.0	452.07	431.79	305.27	324.35
γ 28.0	405.42	388.25	271.61	287.81
γ 29.0	362.52	348.40	241.24	256.18
γ 30.0	323.92	312.69	214.65	227.95
γ 31.0	289.39	280.77	190.63	202.72
γ 32.0	259.10	251.90	169.03	179.70
γ 33.0	231.60	226.46	150.11	158.80
γ 34.0	206.88	203.30	133.56	140.93
γ 35.0	184.75	182.16	119.21	125.22
γ 36.0	164.94	163.24	106.67	111.37
γ 37.0	147.43	146.45	95.76	99.24
γ 38.0	132.24	131.48	86.27	89.04
γ 39.0	118.92	118.33	77.94	80.29
γ 40.0	107.03	106.91	70.60	72.62
γ 41.0	96.72	97.08	64.39	65.94
γ 42.0	87.78	88.28	58.94	60.04
γ 43.0	79.89	80.36	53.97	54.78
γ 44.0	72.86	73.47	49.75	50.20
γ 45.0	66.78	67.28	45.95	46.18
γ 46.0	61.41	61.84	42.52	42.68

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 47.0	56.70	56.99	39.39	39.50
γ 48.0	52.35	52.52	36.59	36.63
γ 49.0	48.40	48.55	34.02	34.07
γ 50.0	44.92	44.94	31.74	31.74
γ 51.0	41.56	41.54	29.62	29.61
γ 52.0	38.59	38.46	27.70	27.75
γ 53.0	35.88	35.68	25.90	26.03
γ 54.0	33.35	33.01	24.21	24.40
γ 55.0	31.01	30.54	22.60	22.91
γ 56.0	28.81	28.25	21.15	21.54
γ 57.0	26.79	26.12	19.72	20.25
γ 58.0	24.87	24.17	18.37	18.98
γ 59.0	23.14	22.36	17.10	17.83
γ 60.0	21.53	20.68	15.92	16.69
γ 61.0	20.01	19.09	14.76	15.65
γ 62.0	18.53	17.58	13.65	14.63
γ 63.0	17.19	16.11	12.55	13.65
γ 64.0	15.87	14.74	11.54	12.66
γ 65.0	14.66	13.49	10.58	11.75
γ 66.0	13.49	12.22	9.72	10.81
γ 67.0	12.37	11.18	8.86	10.02
γ 68.0	11.41	10.15	8.07	9.21
γ 69.0	10.43	9.04	7.38	8.49
γ 70.0	9.57	8.21	6.77	7.88
γ 71.0	8.76	7.47	6.14	7.28
γ 72.0	8.07	6.77	5.55	6.71
γ 73.0	7.40	6.09	5.00	6.13
γ 74.0	6.76	5.46	4.50	5.60
γ 75.0	6.17	4.89	4.01	5.09
γ 76.0	5.62	4.35	3.57	4.62
γ 77.0	5.11	3.86	3.13	4.14
γ 78.0	4.64	3.41	2.78	3.72
γ 79.0	4.17	3.01	2.59	3.45
γ 80.0	3.76	2.76	2.41	3.23
γ 81.0	3.51	2.57	2.24	3.04
γ 82.0	3.30	2.40	2.08	2.86
γ 83.0	3.11	2.23	1.93	2.69
γ 84.0	2.93	2.08	1.79	2.53
γ 85.0	2.76	1.94	1.65	2.34
γ 86.0	2.60	1.80	1.52	2.12
γ 87.0	2.46	1.67	1.34	2.00
γ 88.0	2.30	1.53	1.17	1.83
γ 89.0	2.13	1.34	1.04	1.66
γ 90.0	1.93	1.19	0.97	1.56
γ 91.0	1.75	1.05	0.91	1.47
γ 92.0	1.65	0.99	0.84	1.40
γ 93.0	1.56	0.91	0.76	1.32

IES EQUIVALENT
Photometric Filename:KA9L36BN.IES

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 94.0	1.48	0.85	0.73	1.24
γ 95.0	1.40	0.80	0.66	1.17
γ 96.0	1.32	0.73	0.62	1.11
γ 97.0	1.26	0.69	0.58	1.05
γ 98.0	1.20	0.63	0.54	1.00
γ 99.0	1.13	0.57	0.50	0.96
γ 100.0	1.06	0.53	0.47	0.90
γ 101.0	1.01	0.48	0.43	0.87
γ 102.0	0.96	0.45	0.40	0.83
γ 103.0	0.91	0.40	0.38	0.79
γ 104.0	0.86	0.37	0.36	0.75
γ 105.0	0.81	0.33	0.35	0.72
γ 106.0	0.76	0.30	0.34	0.70
γ 107.0	0.73	0.28	0.32	0.68
γ 108.0	0.69	0.26	0.32	0.66
γ 109.0	0.66	0.22	0.31	0.64
γ 110.0	0.63	0.20	0.31	0.63
γ 111.0	0.60	0.18	0.31	0.62
γ 112.0	0.57	0.17	0.32	0.63
γ 113.0	0.54	0.15	0.33	0.63
γ 114.0	0.53	0.15	0.35	0.62
γ 115.0	0.51	0.14	0.37	0.63
γ 116.0	0.50	0.14	0.39	0.64
γ 117.0	0.49	0.14	0.42	0.67
γ 118.0	0.49	0.16	0.46	0.69
γ 119.0	0.49	0.17	0.50	0.72
γ 120.0	0.49	0.18	0.55	0.76
γ 121.0	0.50	0.21	0.60	0.80
γ 122.0	0.53	0.24	0.65	0.85
γ 123.0	0.55	0.26	0.72	0.90
γ 124.0	0.58	0.31	0.79	0.95
γ 125.0	0.61	0.36	0.86	1.02
γ 126.0	0.66	0.41	0.95	1.08
γ 127.0	0.70	0.47	1.04	1.17
γ 128.0	0.75	0.54	1.13	1.25
γ 129.0	0.83	0.60	1.24	1.34
γ 130.0	0.90	0.69	1.35	1.44
γ 131.0	0.97	0.77	1.46	1.55
γ 132.0	1.05	0.87	1.58	1.65
γ 133.0	1.14	0.96	1.70	1.76
γ 134.0	1.24	1.08	1.84	1.88
γ 135.0	1.35	1.18	1.96	2.00
γ 136.0	1.46	1.30	2.10	2.13
γ 137.0	1.58	1.42	2.23	2.26
γ 138.0	1.70	1.56	2.37	2.39
γ 139.0	1.82	1.70	2.53	2.53
γ 140.0	1.96	1.82	2.67	2.66

IES EQUIVALENT
Photometric Filename:KA9L36BN.IES

Candela Tabulation - (Cont.)

V/H	C0.0	C90.0	C180.0	C270.0
γ 141.0	2.10	1.97	2.82	2.80
γ 142.0	2.22	2.10	2.95	2.93
γ 143.0	2.37	2.24	3.10	3.07
γ 144.0	2.51	2.38	3.24	3.19
γ 145.0	2.65	2.53	3.38	3.34
γ 146.0	2.79	2.68	3.53	3.47
γ 147.0	2.93	2.81	3.65	3.60
γ 148.0	3.07	2.96	3.78	3.71
γ 149.0	3.21	3.09	3.91	3.84
γ 150.0	3.35	3.22	4.04	3.95
γ 151.0	3.48	3.35	4.14	4.06
γ 152.0	3.60	3.47	4.26	4.15
γ 153.0	3.74	3.60	4.36	4.25
γ 154.0	3.85	3.71	4.46	4.35
γ 155.0	3.97	3.82	4.54	4.43
γ 156.0	4.08	3.92	4.63	4.51
γ 157.0	4.17	4.02	4.69	4.57
γ 158.0	4.27	4.11	4.76	4.63
γ 159.0	4.36	4.18	4.81	4.69
γ 160.0	4.44	4.28	4.87	4.73
γ 161.0	4.51	4.34	4.90	4.79
γ 162.0	4.58	4.41	4.94	4.81
γ 163.0	4.64	4.48	4.96	4.85
γ 164.0	4.70	4.53	4.99	4.86
γ 165.0	4.74	4.58	5.00	4.90
γ 166.0	4.79	4.62	5.03	4.91
γ 167.0	4.83	4.66	5.05	4.92
γ 168.0	4.87	4.70	5.06	4.93
γ 169.0	4.91	4.73	5.07	4.94
γ 170.0	4.94	4.76	5.09	4.96
γ 171.0	4.96	4.78	5.10	4.98
γ 172.0	4.99	4.81	5.11	5.00
γ 173.0	5.02	4.84	5.13	5.01
γ 174.0	5.05	4.86	5.14	5.03
γ 175.0	5.08	4.88	5.16	5.04
γ 176.0	5.09	4.91	5.17	5.07
γ 177.0	5.11	4.93	5.18	5.07
γ 178.0	5.14	4.96	5.20	5.08
γ 179.0	5.17	4.99	5.20	5.09
γ 180.0	5.14	5.14	5.14	5.14